

Supervised Living Program II (SLP II) Checklist		
___	Maximum of (6) Children live in home, including natural, foster, and adopted and clients	SCRR 71-8301.3(E)(1)
___	May be in a mobile home or manufactured home if meets certification standards and must not have no more than 2 clients in any mobile home per DDSN Standards	DDSN Standards CTH 1.0
___	Must meet requirements of R-3 occupancies	SCRR 71-8301.3.(E)(1)
___	Listed Smoke Alarm in each bedroom	IFC 907.2.10.1.2(2006)
___	Listed Smoke Alarm in hallway leading to bedrooms	IFC 907.2.10.1.2(2006)
___	Smoke Alarms greater than 10 years old shall be replaced.	NFPA 72-10.4.6 (2007)
___	Smoke Alarms installed per NFPA 72 and manufacturers requirements	SCRR 71-8301.3(E)(1)(a)
___	Homes that have fuel fired appliances shall have a carbon monoxide detector installed in home.	NFPA 72 (2007) 11.9
___	Minimum 2A:10BC fire extinguisher installed in kitchen(s)	SCRR 71-8301.3(E)(1)(b)
___	Fire extinguisher Serviced annually	NFPA 10 7.3.1
___	Fire extinguisher Checked monthly	NFPA 10 7.2.1
___	Minimum (2) independent means of escape as defined in NFPA 101,2009 edition	SCRR 71-8301.3.E(1)(c)
___	Fire escape plan describing actions of family developed, and posted, copy to local fire dept	SCRR 71-8301.3(E)(1)(h)
___	Fire Drill conducted every (3) months	SCRR 71-8301.3(E)(1)(i)
___	Written records of fire drills kept for (3) years	SCRR 71-8301.3(E)(1)(j)
___	Fire Drill conducted within 24 hours of arrival of each new client	SCRR 71-8301.3(E)(1)(k)
___	Heating devices listed Per NFPA and manufacturers recommendations	IFC 603.5
___	Portable kerosene heaters prohibited per the IFC	IFC 603.4 (2006)
___	Portable unvented fuel fired heaters prohibited in CTH homes	SCRR 71-8300.1(E)(1)(l)
___	Unvented gas heaters equipped with Oxygen Depletion Device	SCRR 71-8301.3(E)(1)(f)
___	Approved unvented heaters must comply with NFPA 54 section 9.23.1	SCRR 71-8301.3(E)(1)(f)
___	Unvented gas heaters equipped with automatic gas pilot shutoff device	SCRR 71-8301.3(E)(1)(f)
___	Fireplaces equipped with screens, partitions, or other means to prevent burns	SCRR 71-8301.3(E)(1)(g)
___	Windows in resident bedrooms to comply with IBC/IFC 1026 for emergency egress openings according to width and height and minimum opening size.	IFC 1026 (2006)
___	New home construction must have Smoke Alarms that are interconnected with each other	IFC 907.2.10.3 (2006)
___	Storage of combustible materials shall be neat and orderly per IFC	IFC 315.2 (2006)
___	Storage in attic shall not be excessive and shall be neat and orderly	IFC 315.2 (2006)
___	Working Space not less than 30 inches in front of electrical service equipment	IFC 605.3
___	Breakers shall be labeled	IFC 605.3.1
___	Shall replace missing covers on light fixtures.	NEC 410.5 & 410.6
___	Unused openings in electrical panel shall have filler plates installed to prevent accidental contact or electrical shock.	NEC 110.12(A) & 408.7
___	Open panel box cover(s) shall have a cover installed, repaired or replaced.	NEC 110.12(A)
___	A GFCI outlet or breaker shall be installed for all of the following residential areas: Bathrooms, Garages, Outdoors, Crawlspace, Unfinished basements, Kitchens, Laundry, utility, and Wet bar sinks-where the receptacles are installed within 1.8 M (6 feet) of the outside edge of the sink and the Boathouse.	NEC 210.7
___	Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with the ICC Electrical Code or the NEC shall be prohibited.	IFC 605.4
___	Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.	IFC 605.6
___	Electrical motors shall be maintained free from excessive accumulations of oil, dirt, waste and debris.	IFC 605.8

	Clothes dryers shall be exhausted in accordance with the manufacturer's instructions. Dryer exhaust systems shall be independent of all other systems and shall convey the moisture and any products of combustion to the outside of Clothes dryer transition ducts used to connect the appliance to the exhaust duct system shall be limited to single lengths not to exceed 8 feet (2438 mm) and shall be listed. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of 4 inches (102 mm) in diameter.	IMC 504.1
	Air for combustion, ventilation, and dilution of flue gases for gas utilization equipment installed in buildings shall be obtained by application of methods covered in 8.3.2-8.3.6 of NFPA 54 2006 Ed.	NFPA 54 9.3.1.1
	Portable LP Gas containers as defined in NFPA 58, shall not be used in CTH I homes.	IFC 3803.2.1
	Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances.	IFC 605.5
	Shall provide a minimum of a 1 hour rated separation between each dwelling unit.	IBC 708
	Note: facilities that were constructed to a code that did not require some of these items will not require these items to be installed if they were licensed before these items were required unless the codes specifically require the items to be retroactively required.	